



8 December 2008

Baierboard
565 Sawyers Arms Road,
Harewood,
Christchurch 8013
Att: Jeremy Wang

RE: Baier gypsum internal lining board

Dear Jeremy

In reply to your presentation of information.

The Christchurch City Council Technical committee accepts the use of Baierboard as an internal lining and a limited bracing element, with the following conditions and limitations:

Decision relates to standard internal lining usage and does not include the following applications:


- Specialized bracing, outside the scope of the Baierboard bracing unit ratings and hold down detailing
- Ceiling diaphragms
- Fire protection
- Wet areas
- Acoustic
- Radiation shielding

Decision may be removed at any time; this may be due to changes in:

- Legislation
- Compliance documents
- Standards
- Industry knowledge
- Manufactures literature

Please feel free to contact me at any time regarding this or any other building compliance issues.

Yours faithfully


Graeme Calvert
Senior Building Support Officer
Environmental Policies and Approvals
Christchurch City Council